



City of Wheaton, Illinois

City of Wheaton
303 W. Wesley Street
Wheaton, IL 60187-0727
630-260-2000
www.wheaton.il.us

Concrete Repair: Countryside Reservoir

Invitation to Bid Amendment #1

The following changes / clarifications / additions have been added to the Invitation to Bid project specifications and plans:

1. Attached is the sign-in sheet for the mandatory pre-bid meeting.
2. **QUESTION:** Should the amount for vertical wall repairs be converted from volume of repair to area of repair?
ANSWER: Allowances are based on minimum depth of repair requirements listed under Part 3.02B (Surface Preparation) of Section 03560 CONCRETE SURFACE REPAIR.
3. **QUESTION:** Please clarify daily work hours and work schedule.
ANSWER: Allowable work hours are 7:00am-5:00pm, Monday-Friday. Completion of job is to be within 60 days of award.

Attachments: sign-in sheet for pre-bid meeting

Contacts for this proposal:

Joan M. Schouten CPIM CPPB; Procurement Officer; JSchouten@wheaton.il.us