



City of Wheaton, Illinois

City of Wheaton  
303 W. Wesley Street  
Wheaton, IL 60187-0727  
630-260-2000  
[www.wheaton.il.us](http://www.wheaton.il.us)

---

## POLICE DEPARTMENT FIRING RANGE RENOVATION 2017

---

### Amendment #1

The following changes / clarifications / additions have been added for the above captioned Project, dated July 20, 2017, as follows. All provisions of the original Drawings and Specifications shall remain in force, except as specifically modified or changed herein, or by other Addenda.

1. **CLARIFICATION:** The pre-bid meeting sign-in sheet is attached as a general reference.
2. **CLARIFICATION:** The target system is a fixed clamp system, but targets can be angled.
3. **QUESTION:** Can you please tell me if the electrical is going to be a separate prime bid or if it is all bidding to a General Contractor?  
**ANSWER:** The bid will be awarded to one Contractor.
4. **QUESTION:** It is noted that your baffle design (which is referred to as ballistic panel angle deflector) is typical for a single firing line range, however, the intent outlined in your RFP is 180-degree intentional firing. Are the shooters going downrange? If yes, is there the required concrete ceiling for type of ammo fired above the baffles?  
**ANSWER:** There is an acoustical ceiling in the range with baffles.
5. **QUESTION:** Wall panels – The drawing indicates the covering the trap sidewall areas and approx. 32' back from the trap toe. The spec indicates full 75' coverage. Which is correct?  
**ANSWER:** Install a sufficient quantity of panels to cover the sidewall areas of the bullet trap and continue back 32' from the front of the trap on both (2) sidewalls–up to the illustrated 8' elevation.
6. **QUESTION:** Can wall panels set on the floor – in lieu of being placed 3" up from floor height? There are weight load concerns.  
**ANSWER:** Contractor is to run ballistic wall panels from floor up 8'0".
7. **QUESTION:** Can the front edge of the wall panels simply use a 20-degree angle AR500 armor plate for closure?  
**ANSWER:** Yes.
8. **QUESTION:** Target holders - The drawing shows 17 possible hanging locations (Items labeled A1) – but the spec states 25 locations. Which is correct?  
**ANSWER:** We would like to have (8) extra hangers. We will install 17 of the hangers.
9. **QUESTION:** What is the frequency of use in the range?  
**ANSWER:** Police train outdoors during the warmer month. Range usage is higher during fall/winter.

**Attachments:** Pre-bid sign in sheet

Contacts for this proposal: [LStyczen@wheaton.il.us](mailto:LStyczen@wheaton.il.us)



# The City of Wheaton

Central Purchasing

Project Name: POLICE DEPARTMENT FIRING RANGE RENOVATION

Attending from Wheaton: \_\_\_\_\_

Mandatory Pre-Bid Meeting Date: WEDNESDAY, JULY 26, 2017 at 9:00 a.m.

	Print Name	Title	Company Name	Email Address
1	Jason Laub	President	Laub Construction, Inc	JLaub@Laubconstruction.com
2	Quinton Seearns	President	Spire Ranges	qseearns@spireranges.com
3	Paul Barthel	Manager	MT3 Metal Treatments	PBarthel@elobart1bP.com
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				